

# Spectrum Test Report




**DEKO-LIGHT**  
ELEKTRONIK VERTRIEBS GMBH

<b>Client name:</b>	Deko Light Elektronik Vertriebs GmbH	<b>Report time:</b>	2017-11-02
<b>Item No:</b>	343019	<b>Model name:</b>	Office One m. Sensor

## Results

### Spectrum



CIE 1931 2° observer		CIE 1964 10° observer		Color Parameters	
x	0.3788	x	0.3854	CCT [k]	4064
y	0.3793	y	0.3752	Chromaticity Error	0.003
u'	0.2230	u'	0.2290	Color Peak	450.59
v'	0.5025	v'	0.5016	Color Peak Value	131.12
				Color Dominant	577.9
				Radiometric	18.3712
Rendering Indices		Ra	80.8		
R1	78.5	R8	61.9		
R2	87.2	R9	-0.2	Electrical Parameters	
R3	93.7	R10	69.5	Luminous [lm]	6141.50
R4	79.3	R11	77.4	Luminous Efficacy [lm/W]	79.9675
R5	78.4	R12	55.4	Power [W]	76,8
R6	81.8	R13	80.5	Current [A]	0
R7	85.5	R14	96.6	Voltage [V]	230



Deko-Light Elektronik Vertriebs GmbH

Auf der Hub 2 | D-76307 Karlsbad  
www.deko-light.com  
© Mo. – Fr. 8:00 a.m. – 17:00 p.m.

powered by

